



NOTE  
 1 FOR TRANSFER SWITCHES  
 DEVELOPMENT SEE SH.2112.

LIMIT SW DEVELOPMENT			
EBASCO SYMBOL	CONT.	VALVE OPNG. %	CWD SH.
bo	1-2		*
oc	3-4		*
bo	5-6		*
oc	7-8		*
oc	9-10		*
bc	11-12		*
oc	13-14		*
bc	15-16		*
c %	17-18		*
b %	19-20		*
c %	21-22		*
b %	23-24		*
h %	25-26		*
a %	27-28		*
b %	29-30		*
a %	31-32		*
ic	33-34	OPENS ON OVERLOAD ON CLOSE STROKE	*
to	45-46	OPENS ON OVERLOAD ON OPEN STROKE	*

— CONT. CLOSED \* THIS SYMBOL

PRC  
 APERTURE  
 CARD

**NUCLEAR SAFETY RELATED      WPPSS QUALITY CLASS I**

5 4 3 2 1	EBASCO SERVICES INCORPORATED DIV. CONTROL DR. HSM CH. V. ALKSNINIS DATE OCT. 5, 1973	WASHINGTON PUBLIC POWER SUPPLY SYSTEM NUCLEAR PROJECTS NO. 3 & 5 CONTROL WIRING DIAGRAM ESSENTIAL SERVICES CHILLED WATER PUMP B DISCH VA SEC 800758
APPROVED 	WPPSS-2240 D-6001 SHEET 2952	R

RIDS

8303030517

