



NOTE  
 CONTACT CLOSURES ON ESCW EXP TANK B(SB) HIGH RATE OF CHANGE

LIMIT SW DEVELOPMENT			
EPASCO SYMBOL	CONT.	VALVE OPNG. %	CWD SH.
bo	1-2	0	*
ac	3-4	100	*
bo	5-6	0	*
ac	7-8	100	*
ao	9-10	0	*
bc	11-12	0	*
ao	13-14	0	*
bc	15-16	0	*
a %	17-18	0	*
b %	19-20	0	*
a %	21-22	0	*
b %	23-24	0	*
a %	25-26	0	*
b %	27-28	0	*
a %	29-30	0	*
a %	31-32	0	*
ic	35-36	OPENS ON OVERLOAD ON CLOSE STROKE	*
ic	45-46	OPENS ON OVERLOAD ON OPEN STROKE	*
CONT. CLOSED * THIS SHEET			

PRO APERTURE CARD

NUCLEAR SAFETY RELATED | WPPSS QUALITY CLASS I

EBSACO SERVICES INCORPORATED DIV. CONTROL OR. A.M. CH. V. ALKSNINIS DATE OCT. 9, 1978		WASHINGTON PUBLIC POWER SUPPLY SYSTEM NUCLEAR PROJECTS NO. 3 U 3 CONTROL WIRING DIAGRAM ESSENTIAL SERVICES CHILLED WATER NON ES CW ISOL VA3EC-B0135E		WPPSS-3240 D-6001 SHEET 2953	
REV.	DATE	BY	APPROVED		
1	6-7-82	WV	WV		
2	12-29-81	WV	WV		
3	5-23-80	WV	WV		

REF TO CSD 11-92-8082

RIDS

8303030519

