



NOTES:

1. CONTACT CLOSURE STARTS RECORDER CHART DRIVES PDR-HV4900AS (SH.2970) FR-HV4902AS (SH.2970) PDR-HV4904AS (THIS SHEET) & PDR-HV5039AS (SH.2970)
2. RECORDER PDR-HV4904AS HAS INPUT FROM CHANNEL PD-HV4904AS & PD-HV4905AS.
3. CONTACT OPENS ON HIGH DIFF. PRESS.
4. CONTACT OPENS ON LOW DIFF. PRESS.
5. RECORDER PDR-HV5039AS (SH.2970) HAS INPUT FROM CHANNEL PD-HV4906AS (THIS SHEET).

PRO APERTURE CARD

NUCLEAR SAFETY RELATED WPPSS QUALITY CLASS I

EBA/CO SERVICES INCORPORATED		WASHINGTON PUBLIC POWER SUPPLY SYSTEM	
DIV. CONTROL DR. PAIVA		NUCLEAR PROJECTS NO. 3 & 5	
CH. A. SEN		CONTROL WIRING DIAGRAM	
DATE JUN 9, 1978		HVAC SA INSTRUMENTATION SH. 2	
APPROVED		WPPS-3240	
REV. DATE BY APPROVED		D-6001	
		SHEET 2971	

NO. 10 1287 1-74 4003

RJDS

6303030536

