



- NOTES:
- CONTACT CLOSURE DRIVES DAMPER D-80A TO FULL CLOSE.
 - CONTACT CLOSURE DRIVES DAMPER D-80A TO FULL CLOSE.
 - CONTACT CLOSURE DRIVES DAMPER D-80A TO FULL CLOSE.
 - CONTROLLER M/A STATION IS LOCATED IN CP-50.
 - CONTACT CLOSURE DRIVES VALVE TCV-HV4911AS TO FULL CLOSE.
 - CONTACT OPENS ON LOW DIFF PRESS.
 - CONTACT OPENS ON HIGH DIFF PRESS.
- * - THIS SHEET

PRC
APERTURE
CARD

5		NUCLEAR SAFETY RELATED		WPPSS QUALITY CLASS I	
4		EBAECO SERVICES INCORPORATED		WASHINGTON PUBLIC POWER SUPPLY SYSTEM	
3		DIV. CONTROL DR. PAIVA		NUCLEAR PROJECTS NO. 3 & 5	
2		CH. A. SEN		CONTROL WIRING DIAGRAM	
1		DATE JUN 9, 1978		HVAC SA INSTRUMENTATION SH. 4	
REV.	DATE	BY	APPROVED	WPPS-3240	
				D-6001	
				SHEET 2973	

RIDS

8303030542

