



- NOTES**
- CONTACT CLOSURE DRIVES THE DAMPERS D-90A, D-92A, D-93A TO FULL CLOSE.
 - CONTROLLER M/A STATION IS LOCATED IN CP-50
 - CONTACT OPENS ON HIGH TEMP.

LEGEND
* - THIS SHEET

PRC
APERTURE
CARD

NUCLEAR SAFETY RELATED WPPSS QUALITY CLASS I

5									
4									
3									
2	7-23-82	PK	NA	PD	EBASCO SERVICES INCORPORATED	WASHINGTON PUBLIC POWER SUPPLY SYSTEM	NUCLEAR PROJECTS NO. 3 & 5	CONTROL WIRING DIAGRAM	WPPS-3240
1	7-22-81	RIP	NA	3-85	DIV. CONTROL DR. C. KIM	APPROVED	NUCLEAR PROJECTS NO. 3 & 5	HVAC SA INSTRUMENTATION SH. 5	D-6001
REV	DATE	BY	APPROVED		DATE JUN 9, 1978				SHEET 2974

RIDS

8303030544

