



- NOTES
1. CONTACT CLOSES AT TEMP GREATER OR EQUAL TO 104° F.
 2. CONTACT OPENS AT TEMP LESS OR EQUAL TO 100° F.
 3. CONTACT OPENS ON HIGH TEMP.

REV	DATE	BY	APPROVED
5			
4			
3			
2	3-26-82	RJP	J.A. PDS
1	8-7-81	PWT	J.A. PDS

EBASCO SERVICES INCORPORATED
 DIV. CONTROL DR. PAIVA
 CH. A. SEN
 DATE JUN 9, 1973
 APPROVED
 D.D. Price

NUCLEAR SAFETY RELATED | WPPSS QUALITY CLASS I
 WASHINGTON PUBLIC POWER SUPPLY SYSTEM
 NUCLEAR PROJECT NO 3
 CONTROL WIRING DIAGRAM
 HVAC SB INSTRUMENTATION SH. 9

WPPS-3240
 D-6001
 SHEET 2990

R.R.C.
 APERTURE
 CARD

RIDS

8303030585

