



- \* - THIS SHEET  
NOTES
- CONTACT OPENS ON LOW DIFF. PRESS.
  - FOR TRANSFER DEVICE OF CHANNEL T-HV5001A REFER TO SH. 2996.
  - CONTACT OPENS ON HIGH DIFF. PRESS.
  - CONTACT OPENS ON HIGH TEMPERATURE.
  - CONTACT OPENS ON LOW TEMPERATURE.
  - CONTACT OPENS WHEN CONTROL IS TRANSFERRED TO REMOTE SHUTDOWN PANEL.

EASCO SERVICES INCORPORATED			
3	3-5-82	RTP	V.A.
4	5-12-81	RTP	V.A.
5	10-22-79	A.S.	V.A.
REV.	DATE	BY	APPROVED
			DATE JUN 9, 1978

WASHINGTON PUBLIC POWER SUPPLY SYSTEM		WPPS-3240	
NUCLEAR PROJECTS NO. 3 & 5		D-6001	
CONTROL WIRING DIAGRAM		SHEET 2995	
HVAC INSTRUMENTATION SH. 2		R	

PRC APERTURE CARD

WPPSS QUALITY CLASS II

11

11

8.5

8.5"

11"

17"



RIDS

8303030590

