



- NOTES**
1. TS OPERATES TRANSFER DEVICES FOR CHANNELS T-HV5001D (SH. 2994); T-HV5001A (SH. 2995); T-HV5001B; T-HV5001C (THIS SHEET).
  2. CONTACT CLOSURE CLOSES VALVE TCV-HV5001B.
  3. CONTACT CLOSURE CLOSES VALVE TCV-HV5001C.
  4. CONTACT OPENS ON HIGH TEMP.
  5. CONTACT CLOSURE CLOSES VALVE TCV-HV5001A (SH. 2995).
  6. CONTACT CLOSURE CLOSES VALVE TCV-HV5001D (SH. 2994).
  7. CONTACT OPENS ON CONTROLLER TROUBLE OR SETPOINT DEVIATION BETWEEN CONTROL BOARD & RSP.

**LEGEND**  
 [ ] - REPRESENTS MFR CABLE SERIAL NO.  
 \* - THIS SHEET

WPSS QUALITY CLASS II

REV.	DATE	BY	APPROVED	ERASCO SERVICES INCORPORATED
1	7-6-82	W.A.	[Signature]	DIV. CONTROL DR. C. KIM
2	3-5-82	R.P.	[Signature]	CH. A. SEN
3	9-4-81	R.P.	[Signature]	DATE JUN 9, 1978
4	10-22-79	A.R.	[Signature]	

WASHINGTON PUBLIC POWER SUPPLY SYSTEM  
 NUCLEAR PROJECT NO 3  
 CONTROL WIRING DIAGRAM  
 HVAC INSTRUMENTATION SH. 3

WPSS-3240  
 D-6001  
 SHEET 2996

PRC APERTURE CARD

11

11

11

8.5"

11"

17



RIDS

8303030592

