



NOTE
1. INDICATING LIGHTS
TO BE SQUARE D
CO. TYPE K, CLASS
9001 KP-38A9 OR
KP-38G9 AS REQD.

PRC
APERTURE
CARD

5 1-29-82 4 7-22-81 3 1-12-81 2 4-14-79 1 1-11-78 REV DATE BY APPROVED		EASCO SERVICES INCORPORATED DIV. CONTROL DR. LVT CH. DR. JORDAN DATE MAR 29, 1976 APPROVED <i>Richard</i> S. H. PAVEL, AT TEN 113	WASHINGTON PUBLIC POWER SUPPLY SYSTEM NUCLEAR PROJECTS NO. 3 & 5 CONTROL WIRING DIAGRAM SAFEGUARDS EQUIPMENT ROOM B FD #2 SUMP PUMPS A & B	WPPSS-3240 D6001 SHEET 3193
---	--	---	---	-----------------------------------

RIDS

8303030606

