



NOTE:
1. JUMPER BY FIELD

LIMIT SW DEVELOPMENT			
EBASCO SYMBOL	CONT.	VALVE OPNG. %	CWD SH.
		0	
		100	
bo	1-2		*
ac	3-4		*
bo	5-6		*
ac	7-8		*
ao	9-10		
bc	11-12		
ao	13-14		*
bc	15-16		*
a %	17-18		
b %	19-20		
a %	21-22		
b %	23-24		
a %	25-26		
a %	27-28		
b %	29-30		
a %	31-32		
ic	35-36	OPENS ON OVERLOAD ON CLOSE STROKE	*
to	45-46	OPENS ON OVERLOAD ON OPEN STROKE	*
		CONT. CLOSED	* THIS SHEET

PRC APERTURE CARD

NUCLEAR SAFETY RELATED WPPSS QUALITY CLASS I

5 4 3 2 7-23-82 PW LVT N.A. JBP 1 4-23-80 RJP N.A. RL JBP REV. DATE BY APPROVED				EBASCO SERVICES INCORPORATED DIV. CONTROL DR. C KIM CH. A. R. RAO DATE JAN 29, 1980		APPROVED WASHINGTON PUBLIC POWER SUPPLY SYSTEM NUCLEAR PROJECTS NO. 3 & 5 CONTROL WIRING DIAGRAM RB FIRE WATER HEADER ISO VA ZFP-VH0065		WPPSS-3240 D-6001 SHEET 3412	
--	--	--	--	--	--	--	--	------------------------------------	--

RIDS

8303030618

