



NOTE:  
I JUMPER BY FIELD

LIMIT SW DEVELOPMENT				
EBASCO SYMBOL	CONT.	VALVE OPNG. %		CWD S.I.
		0	100	
bo	1-2			*
oc	3-4			*
bc	5-6			*
oc	7-8			*
ao	9-10			*
bc	11-12			*
ao	13-14			*
bc	15-16			*
a %	17-18			*
b %	19-20			*
a %	21-22			*
b %	23-24			*
b %	25-26			*
a %	27-28			*
b %	29-30			*
a %	31-32			*
tc	35-36	OPENS ON OVERLOAD ON CLOSE STROKE		*
to	45-46	OPENS ON OVERLOAD ON OPEN STROKE		*
		CONT. CLOSED	* THIS SHEET	

PRC APERTURE CARD

NUCLEAR SAFETY RELATED WFPSS QUALITY CLASS I

5 4 3 2 1 REV. DATE BY APPROVED				<b>EBASCO SERVICES INCORPORATED</b> DIV. CONTROL DR. C KIM CH. A R RAC DATE JAN 29, 1980		APPROVED 		WASHINGTON PUBLIC POWER SUPPLY SYSTEM NUCLEAR PROJECTS NO. 3 & 5 CONTROL WIRING DIAGRAM RB SPRINKLER SYST ISO VA 2FP-VHC05SB		WPPS-3240 D-6001 SHEET 3413	
--	--	--	--	---	--	--------------	--	--	--	-----------------------------------	--



RIDS

8303030622

