

17"



11"

8.5"

17"

11"

8.5"



EQUIPMENT	CABLE NO.	EQUIPMENT
125V DC DISTR PNL SC	A-SC	SUPS-C-SC INVERTER
125V DC DISTR PNL SC	B-SC	13, 8KV SWGR RCP-SA
125V DC DISTR PNL-SA	C-SA	SUPS-A-SA INVERTER
	D-SA	480V PWR CTR A31-SA
	E-SA	480V PWR CTR A32-SA
	F-SA	4, 16KV SWGR A3-SA
	G-SA	125V DC LTG PNL NO. 41
125V DC DISTR PNL-SB	H-SB	125V DC LTG PNL NO. 40
	J-SB	SUPS-B-SB INVERTER
	K-SB	480V PWR CTR B31-SB
	L-SB	480V PWR CTR B32-SB
	M-SB	4, 16KV SWGR B3-SB

EQUIPMENT	CABLE NO.	EQUIPMENT
125V DC DISTR PNL-SD	N-SD	13, 8KV SWGR RCP-SB
	P-SD	SUPS-D-SD INVERTER
	Q	
	R	
	S	
	T	
	U	
	V	
	W	
	X	
	Y	
	Z	

8.5"

11"

17"

8.5"

11"

17"

PRC APERTURE CARD

NUCLEAR SAFETY RELATED WPPSS QUALITY CLASS I&II

5									
4									
3									
2									
1									
REV.	DATE	BY	APPROVED	EDASCO SERVICES INCORPORATED			WASHINGTON PUBLIC POWER SUPPLY SYSTEM		WFPS-3240
				DIV. CONTROL OR. S.P.			NUCLEAR PROJECTS NO. 3 & 5		D-6001
				CH. M. REGA			CONTROL WIRING DIAGRAM		SHEET 3916
				DATE NOV 21, 1980			LIGHTING & POWER FEEDERS, SH. 17		

RIDS

8303030645

