



- NOTES
1. FIELD TO WIRE CONTACT TO TERMINAL BLOCK AS SHOWN
 2. LIGHT ACTUATING CONTACT CLOSURE WILL MAKE INDICATING LIGHTS GLOW BRIGHT. ON CONTACT OPENING LIGHTS WILL GLOW DIM.

PRC
APERTURE
CARD

NUCLEAR SAFETY RELATED WPPSS QUALITY CLASS I

EASCO SERVICES INCORPORATED		WASHINGTON PUBLIC POWER SUPPLY SYSTEM		WPPS-3240	
DIV. CONTROL DR. PJP		APPROVED		D-6001	
CH. L. TANENBAUM		DATE APR 20, 1981		HPSI & LPSI SYSTEM 33 STATUS DISPLAY	
REV. DATE BY APPROVED				SH. 2149	

RIDS

8303040288

