



NOTE
 1. FIELD TO VERIFY IF JUMPERS ARE INSTALLED. IF NOT FIELD TO ADD JUMPERS.

LIMIT SW DEVELOPMENT			
EBASCO SYMBOL	CONT.	VALVE OF HG. %	CWD SH.
		0	100
bo	1-2		*
ac	3-4		*
bo	5-6		*
ac	7-8		*
ao	9-10		*
bc	11-12		*
ao	13-14		*
bc	15-16		*
a %	17-18		2153
b %	19-20		
a %	21-22		
b %	23-24		
b %	25-26		
a %	27-28		
b %	29-30		
a %	31-32		
1c	35-36	OPENS ON OVERLOAD ON CLOSE STROKE	*
1a	45-46	OPENS ON OVERLOAD ON OPEN STROKE	*

CONT. CLOSED * THIS SHEET

PRO APERTURE CARD

MOV. LIMIT SWITCHES (NOTE 1)

NUCLEAR SAFETY RELATED WPPSS QUALITY CLASS I

5-28-82 RVP N.R. 32-34 5-29-82 RVP N.R. 32-34 11-17-78 A.R. G.D. 11-17-78				EBASCO SERVICES INCORPORATED DIV. CONTROL DR. LVT CH. E. OVALLE DATE: MAY 5, 1977		APPROVED <i>[Signature]</i> WPPSS QUALITY CLASS I		WASHINGTON PUBLIC POWER SUPPLY SYSTEM NUCLEAR PROJECTS NO. 3 & 5 CONTROL WIRING DIAGRAM HPSI 2 HOT LEG FLOW CONTROL VA 25F-VQ173SBR(S1 331)		WPPS-3240 D-6001 SHEET 2154	
---	--	--	--	--	--	---	--	---	--	-----------------------------------	--

RIDS

8303040297

