



NOTE
I. JUMPER BY FIELD

| LIMIT SW DEVELOPMENT | | | |
|----------------------|---------|-----------------------------------|---------|
| EBASCO SYMBOL | CONT. | VALVE OPNG. % | CWD SH. |
| bo | 3-3C | 0 | * |
| ac | 7-7C | 100 | * |
| bo | 4-4C | | * |
| ac | 8-8C | | * |
| ao | 1-1C | | * |
| bc | 5-5C | | (2149) |
| bc | 6-6C | | * |
| a % | 15-15C | | |
| b % | 11-11C | | |
| a % | 16-16C | | |
| b % | 12-12C | | |
| a % | 13-13C | | |
| a % | 9-9C | | |
| b % | 14-14C | | |
| a % | 10-10C | | |
| 1c | 117-17C | OPENS ON OVERLOAD ON CLOSE STROKE | * |
| 1o | 118-18C | OPENS ON OVERLOAD ON OPEN STROKE | * |

— CONT. CLOSED * THIS SHEET

PRG APERTURE CARD

| | | | | |
|--|---|---|--|-----------------------------------|
| NUCLEAR SAFETY RELATED WPPSS QUALITY CLASS I | | WASHINGTON PUBLIC POWER SUPPLY SYSTEM NUCLEAR PROJECTS NO. 3 & 5 CONTROL WIRING DIAGRAM HPSI, NBR. 5 TO LOOT 2A VA SI-01 (ZSI-VQ019SBR) | | WPPS-3240 D-6001 SHEET 2162 |
| EBASCO SERVICES INCORPORATED DIV. CONTROL DR. LVT CH. E. O'VALLE DATE MAY 5, 1977 | | APPROVED | | |
| REV. DATE BY APPROVED | 1 2 6-22-82 WJP VA 3 5-25-83 WJP VA | | | |

RIDS

8303040311

