



NOTE
I. JUMPER BY FIELD.

LIMIT SW DEVELOPMENT			
SYMBOL	CONT.	VALVE OPNG. %	CYD SH.
ba	3-3C	100	
ac	7-7C		
ba	4-4C		
ac	8-8C		
aa	1-1C		
bc	5-5C		
aa	2-2C		12148
ba	6-6C		
a %	115-15C		
b %	11-11C		
a %	16-16C		
b %	12-12C		
b %	13-13C		
a %	9-9C		
b %	14-14C		
a %	10-10C		
1c	17-17C	OPENS ON OVERLOAD ON CLOSE STROKE	
1o	18-18C	OPENS ON OVERLOAD ON OPEN STROKE	
--- CONT. CLOSED * THIS SHEET			

PRO
APERTURE
CARD

NUCLEAR SAFETY RELATED WPPSS QUALITY CLASS I

EBASCO SERVICES INCORPORATED DIV. CONTROL DR. LVT CH. E. OVALLE DATE MAY 5, 1977		APPROVED 		WASHINGTON PUBLIC POWER SUPPLY SYSTEM NUCLEAR PROJECTS NO. 3 & 5 CONTROL WIRING DIAGRAM HPSI HDR A TO LOOP 2A VA SI-617 (2SI-V00205AR)		WPPSS-24C D-6001 SHEET 2163	
---	--	--------------	--	--	--	-----------------------------------	--

RIDS

8303090439

