


CONTACT	POSITION FRONT VIEW			CWD
	CLOSE	AUTO	SPENSAS O-RIDE	
1	X			*
2			X	*
3	X			*
4			X	*

SPRING RETURN TO AUTO WITH KEY LOCK, KEY REMOVABLE IN AUTO POS ONLY.
* THIS SHEET

- NOTES:
1. DURING REACTOR OPERATION, BKR COMPT IS PADLOCKED IN THE TRIP POSITION.
 2. N/C CONTACT OPENS WHEN DECREASING RCS PRESS IS < 415 PSIA AND CLOSES WHEN INCREASING RCS PRESS IS > 500 PSIA.
 3. N/O CONTACT OPENS WHEN THE RCS PRESS IS > 500 PSIA & CLOSES WHEN THE RCS PRESS IS < 415 PSIA.
 4. TS TRANSFER SWITCH DEVELOPMENT IS SHOWN ON SH-212.
 5. ALL JUMPERS BY FIELD.

LIMIT SW DEVELOPMENT			
EBASCO SYMBOL	CONT.	VALVE OPNG. %	CWD SH.
bc	1-2	0	*
ac	3-4		*
bc	5-6		*
ac	7-8		*
aa	9-10		*
bc	11-12		*
ac	13-14		*
bc	15-16		*
a %	17-18		*
b %	19-20		*
a %	21-22		*
b %	23-24		*
a %	25-26		*
b %	27-28		*
a %	29-30		*
a %	31-32		*
tc	35-36	OPENS ON OVERLOAD ON CLOSE STROKE	*
tc	35-36	OPENS ON OVERLOAD ON OPEN STROKE	*
tc	35-36	OPENS ON OVERLOAD ON OPEN STROKE	*

PRO APERTURE CARD



EGASCO SERVICES INCORPORATED
 DESIGNED BY: [Signature]
 CHECKED BY: [Signature]
 DATE: MAY 5, 1977

WASHINGTON PUBLIC POWER SUPPLY SYSTEM
 NUCLEAR PROJECTS NO. 3 & 4
 CONTROL WIRING DIAGRAM
 STATION 1 ISOLATION
 WPPS-3240
 8-0001
 5-7-74

8.5"
11"
17"

RIDS

8303090452

