



NOTE
I. JUMPER BY FIELD

LIMIT SW DEVELOPMENT			
EBASCO SYMBOL	CONT.	VALVE OPNG %	
		0	100
ba	3-3C		
ac	7-7C		*
ba	4-4C		
ac	6-6C		
aa	1-1C		
bc	5-5C		
aa	2-2C		(2148)
bc	6-6C		
a %	15-15C		
b %	11-11C		
a %	16-16C		
b %	12-12C		
b %	13-13C		
a %	19-19C		
b %	14-14C		
a %	10-10C		
1c	17-17C	OPENS ON OVERLOAD ON CLOSE STROKE	
1o	18-18C	OPENS ON OVERLOAD ON OPEN STROKE	
--- CONT. CLOSED * THIS SHEET			

PRC APERTURE CARD

NUCLEAR SAFETY RELATED WPPSS QUALITY CLASS I

EBASCO SERVICES INCORPORATED		APPROVED	
REV. DATE BY APPROVED	DATE MAY 5 1977	LIMITED	
5			
4			
3			
2	6-27-81		
1	5-29-80		

WASHINGTON PUBLIC POWER SUPPLY SYSTEM
 NUCLEAR PROJECTS NO. 3 B 5
 CONTROL WIRING DIAGRAM
 HISHER A TO LOOP A
 VA-SI-677 (251-VQ145A1)

WPPS-3240
 D-6001
 SHEET 2183

BIDS

8303090498

