


CONTACT	POSITION FRONT VIEW			CWD
	CLOSE	AUTO	OPEN/AL-ORDE	
1	X			*
2			X	*
3	X			*
4			X	*

SPRING RETURN TO AUTO WITH KEY LOCK, KEY REMOVABLE IN AUTO POS ONLY.
* THIS SHEET

- NOTES:
- DURING REACTOR OPERATION, BKR COMPT IS PADLOCKED IN THE TRIP POSITION.
 - N/C CONTACT OPENS WHEN DECREASING RCS PRESS IS < 415 PSIA AND CLOSES WHEN INCREASING RCS PRESS IS > 500 PSIA.
 - N/O CONTACT OPENS WHEN THE RCS PRESS IS > 500 PSIA & CLOSES WHEN THE RCS PRESS IS < 415 PSIA.
 - TS TRANSFER SWITCH DEVELOPMENT IS SHOWN ON SH. 2111.
 - ALL JUMPERS BY FIELD.

EBASCO SYMBOL	CO-IT.	LIMIT SW DEVELOPMENT		CWD SH.
		VALVE OPNG. %		
bo	1-2			*
ac	3-4			*
bo	5-6			*
ac	7-8			*
ao	9-10			*
bc	11-12			*
ao	13-14			*
bc	15-16			*
a %	17-18			*
b %	19-20			*
a %	21-22			*
b %	23-24			*
d %	25-26			*
a %	27-28			*
b %	29-30			*
a %	31-32			*
1c	35-36	OPENS ON OVERLOAD ON CLOSE STROKE		*
1o	45-46	OPENS ON OVERLOAD ON OPEN STROKE		*

PRC APERTURE CARD



REV	DATE	BY	APPROVED	REV.	DATE	BY	APPROVED
10				12-15-81	RJP	VA	PSA
9				5-8-81	RJP	VA	PSA
8				4-28-80	CS	VA	PSA
7				2-8-77	AR	VA	PSA
6	6-25-82	VA	PSA	10-23-78	AR	VA	PSA

EBASCO SERVICES INCORPORATED
 DIV. CONTROL DR. LVT
 CH. E DVALVE
 DATE MAY 5 1977

NUCLEAR SAFETY RELATED WPPSS QUALITY CLASS I
 WASHINGTON PUBLIC POWER SUPPLY SYSTEM
 NUCLEAR PROJECTS NO. 3 & 5
 CONTROL WIRING DIAGRAM
 SI TANK 3 ISOLATION
 VA 151 - VP1075AR (SI-634)
 WPPSS-3240
 D-6001
 SHEET 2157

44 11
44 11
44 58
88
10
137

44 11
44 11
44 58
88
8.5"
11"
17"

RIDS

8303090508

