



NOTE
I. JUMPER BY FIELD

LIMIT SW DEVELOPMENT			
EBASCO SYMBOL	CONT.	VALVE OPNG. %	CWD SH.
bo	3-3C	0	
ac	7-7C	100	
bo	4-4C		
ac	8-8C		
ac	1-1C		
bc	5-5C		
ac	7-2C		2148
bc	6-6C		
a %	15-15C		
b %	11-11C		
a %	16-16C		
b %	12-12C		
b %	13-13C		
a %	9-9C		
b %	14-14C		
a %	10-10C		
tc	17-17C	OPENS ON OVERLOAD ON CLOSE STROKE	
to	18-18C	OPENS ON OVERLOAD ON OPEN STROKE	

— CONT. CLOSED * THIS SHEET

PRO APERTURE CARD

NUCLEAR SAFETY RELATED WPPSS QUALITY CLASS I

EBASCO SERVICES INCORPORATED		WASHINGTON PUBLIC POWER SUPPLY SYSTEM		WPPSS-3240 D-6001 SHEET 2/93
DIV. CONTROL DR. LVT CM. E. OYALLE		APPROVED <i>[Signature]</i>		
REV. 1	DATE 6-22-82	BY V.A. 228	DATE MAY 5 1977	
REV. 2	DATE	BY	APPROVED	

HPSI-HDR. A TO LOOP 1B
 VA 01-647 (2SI-VQ0095AR)

RIDS

8303090539

