


CONTACT	POSITION FRONT VIEW			CWD
	CLOSE	AUTO	OPEN/IAS O/RDB	
1	X			*
2			X	*
3	X			
4			X	*

SPRING RETURN TO AUTO WITH KEY LOCK, KEY REMOVABLE IN AUTO POS ONLY.  
\* THIS SHEET

- NOTES:
- DURING REACTOR OPERATION, BKR COMPT IS PADLOCKED IN THE TRIP POSITION.
  - N/C CONTACT OPENS WHEN DECREASING RCS PRESS IS < 415 PSIA AND CLOSES WHEN INCREASING RCS PRESS IS > 500 PSIA.
  - N/O CONTACT OPENS WHEN THE RCS PRESS IS > 500 PSIA & CLOSES WHEN THE RCS PRESS IS < 415 PSIA.
  - TS TRANSFER SWITCH DEVELOPMENT IS SHOWN ON SH.211.
  - ALL JUMPERS BY FIELD.

LIMIT SW DEVELOPMENT			
EBASCO SYMBOL	CONT.	VALVE OPNG. %	CWD SH.
		0	100
ba	1-2		*
ac	3-4		
ba	5-6		*
ac	7-8		*
ca	9-10		*
bc	11-12		*
ca	13-14		*
bc	15-16		*
a %	17-18		
b %	19-20		
a %	21-22		
b %	23-24		
b %	25-26		
a %	27-28		
b %	29-30		
a %	31-32		
1c	35-36	OPENS ON OVERLOAD ON CLOSE STROKE	*
1a	45-46	OPENS ON OVERLOAD ON OPEN STROKE	*

PRO APERTURE CARD



REV	DATE	BY	APPROVED	REV	DATE	BY	APPROVED
10				1	1-15-81	RPT	
9				2	5-8-81	RPT	
8				3	6-29-80	RPT	
7				4			
6	6-25-82	W. J. H.		5			

EBASCO SERVICES INCORPORATED  
DIV. CONTROL DR. I.V.T.  
CH. E. DVA  
DATE MAY 5 1971

APPROVED  
WASHINGTON PUBLIC POWER SUPPLY SYSTEM  
NUCLEAR PROJECTS NO. 3 & 5  
CONTROL WIRING DIAGRAM  
SI TANK + ISOLATION  
VA 151 - VPI-15R (SI-6/4)

WPPSS-3240  
D-6001  
SHEET 21/27

NUCLEAR SAFETY RELATED WPPSS QUALITY CLASS I

RIDS

8303090546

