



- NOTES:
1. N/C CONTACT OPENS WHEN DECREASING RCS PRESS IS < 400 PSIA AND CLOSSES WHEN INCREASING RCS PRESS IS > 500 PSIA.
 2. N/O CONTACT OPENS WHEN THE RCS PRESS IS > 500 PSIA & CLOSSES WHEN THE RCS PRESS IS < 400 PSIA.
 3. TS TRANSFER SWITCH DEVELOPMENT IS SHOWN ON SH. 2111.

LIMIT SW DEVELOPMENT			
EBASCO SYMBOL	CONT.	VALVE OPNG. %	CWD SH.
bo	1-2	0	
ac	3-4	100	*
bo	5-6		
ac	7-8		*
ao	9-10		
bc	11-12		*
ao	13-14		
bc	15-16		*
a %	17-17		
b %	19-20		
a %	21-22		
b %	23-24		
a %	25-26		
b %	27-28		
a %	29-30		
a %	31-32		
1c	35-36	OFFENSIVE OVERLOAD ON CLOSE STROKE	*
1o	45-46	OFFENSIVE OVERLOAD ON OPEN STROKE	*

CONT CLOSED * THIS SHEET

P/R C APERTURE CARD

NUCLEAR SAFETY RELATED WPPSS QUALITY CLASS 1

EBASCO SERVICES INCORPORATED

WASHINGTON PUBLIC POWER SUPPLY SYSTEM

NUCLEAR PROJECTS NO. 3 & 5

CONTROL WIRING DIAGRAM

SHUTDOWN COOLING LOOP SUCT

ISC VA IS-VF092SAR (SI-651)

REV.	DATE	BY	APPROVED
1	12-15-81
2	5-22-81
3	8-7-79
4	10-9-78

APPROVED

DATE

WPPSS-3240

D-6001

SHEET 2205

44 LL

44 LL

44 5.8

44 LL

44 LL

44 5.8

8.5"

11"

17"

RIDS

8303090553

