


CONTACT	POSITION FRONT VIEW			CWD
	CLOSE	AUTO	OPEN	
1			X	*
2	X			*
3		X		*
4		X		

SPRING RETURN TO AUTO WITH KEY LOCK, KEY REMOVABLE IN AUTO POSITION ONLY.
* THIS SHEET

- NOTES:
- N/O CONTACT OPENS WHEN THE RCS PRESSURE IS > 500 PSIA & CLOSSES WHEN THE RCS PRESSURE IS < 400 PSIA.
 - N/C CONTACT OPENS WHEN DECREASING RCS PRESSURE IS < 400 PSIA & CLOSSES WHEN INCREASING RCS PRESSURE IS > 500 PSIA.



PRO APERTURE CARD

NUCLEAR SAFETY RELATED WPPSS QUALITY CLASS I

EBASCO SERVICES INCORPORATED DIV. CONTROL DR. FAIVA CH. A.R. RAO DATE AUG 7, 1978		WASHINGTON PUBLIC POWER SUPPLY SYSTEM NUCLEAR PROJECTS NO 3 & 5 CONTROL WIRING DIAGRAM SHUTDOWN COOLING LOOP 1 RETURN VA IS1-VP091SAR (SI-653)		WPPS-3240 D-6001 SHEET 2206
REV.	DATE	BY	APPROVED	
5				
4				
3				
2				
1				

17"
11"
8.5"
11"
8.5"
17"

17"
11"
8.5"
11"
8.5"
17"

RIDS

8303090557

