



- NOTES:
1. N/C CONTACT OPENS WHEN DECREASING RCS PRESS IS < 400 PSIA AND CLOSSES WHEN INCREASING RCS PRESS IS > 500 PSIA.
  2. N/O CONTACT OPENS WHEN THE RCS PRESS IS > 500 PSIA & CLOSSES WHEN THE RCS PRESS IS < 400 PSIA.
  3. TS TRANSFER SWITCH DEVELOPMENT IS SHOWN ON SH. 2112.

LIMIT SW DEVELOPMENT			
EBASCO SYMBOL	CONT.	VALVE OPNG. %	CWD SH.
	0	100	
bo	1-2		*
ac	3-4		*
bo	5-6		*
ac	7-8		*
ao	9-10		*
bc	11-12		*
ao	13-14		*
bc	15-16		*
a %	17-18		*
b %	19-20		*
a %	21-22		*
b %	23-24		*
b %	25-26		*
a %	27-28		*
b %	29-30		*
a %	31-32		*
1c	35-36	OPENS ON OVERLOAD ON CLOSE STROKE	*
1o	45-46	OPENS ON OVERLOAD ON OPEN STROKE	*

CONT. CLOSED \* THIS SHEET

R.P.C. APERTURE CARD

REV.	DATE	BY	APPROVED
1	12-15-81	EV	VA
2	6-20-81	EV	VA
3	7-73	AR	EV
4	10-9-73	AR	EV

EBASCO SERVICES INCORPORATED  
 DIV. CONTROL DR. L.V.T.  
 CH. E. OVALLE  
 DATE MAY 5, 1977

WASHINGTON PUBLIC POWER SUPPLY SYSTEM  
 NUCLEAR PROJECTS NO. 3 & 5  
 CONTROL WIRING DIAGRAM  
 SHUTDOWN COOLING LOOP 2 SUCT.  
 150 VA 151-VP095SER (SI-652)

WPPS-3240  
 D-6001  
 SHEET 2210

KBR 10 1288 11-71 606230



RIDS

8303090563

