



- NOTES:
1. N/O CONTACT OPENS WHEN DECREASING RCS PRESS IS < 400 PSIA AND CLOSSES WHEN INCREASING RCS PRESS IS > 500 PSIA.
 2. N/O CONTACT OPENS WHEN THE RCS PRESS IS > 500 PSIA & CLOSSES WHEN THE RCS PRESS IS < 400 PSIA.
 3. TS TRANSFER SWITCH DEVELOPMENT IS SHOWN ON SH. 2112.

LIMIT SW DEVELOPMENT			
EBASCO SYMBOL	CONT.	VALVE OPNG. %	CWD SH.
		100	
bc	1-2		*
ac	3-4		*
bo	5-6		*
ac	7-8		*
ao	9-10		*
bc	11-12		*
ao	13-14		*
bc	15-16		*
a %	17-18		*
b %	19-20		*
a %	21-22		*
b %	23-24		*
b %	25-26		*
a %	27-28		*
b %	29-30		*
a %	31-32		*
1c	35-36	OPENS ON OVERLOAD ON CLOSE STROKE	*
1o	45-46	OPENS ON OVERLOAD ON OPEN STROKE	*

--- CONT. CLOSED * THIS SHEET

PRO APERTURE CARD

NUCLEAR SAFETY RELATED WPPSS QUALITY CLASS I

EBASCO SERVICES INCORPORATED DIV. CONTROL DR. LVT CH. E. OVALLE DATE MAY 5, 1977		WASHINGTON PUBLIC POWER SUPPLY SYSTEM NUCLEAR PROJECTS NO. 3 & 5 CONTROL WIRING DIAGRAM SHUTDOWN COOLING LOOP 2 SUCTION ISO V/A 251-VU041SBR (SI-654)		WPPS-3240 D-6001 SHEET 2212	
REV.	DATE	BY	APPROVED	APPROVED <i>[Signature]</i>	

41
11
8.5"
11"
8.5"
17"

RIDS

8303090570

