



- NOTES:
1. TS TRANSFER SWITCH DEVELOPMENT IS SHOWN ON SH 2111.
 2. ALL JUMPERS BY FIELD

LIMIT SW DEVELOPMENT			
EBASCO SYMBOL	CONT.	VALVE OPNG. %	CWP SH.
do	1-2	0	100
ac	3-4		*
bo	5-6		*
ac	7-8		*
ao	9-10		*
bc	11-12		*
ac	13-14		*
bc	15-16		*
a %	17-18		*
b %	19-20		*
a %	21-22		*
b %	23-24		*
b %	25-26		*
a %	27-28		(2143)
b %	29-30		*
a %	31-32		*
1c	33-36	OPENS ON OVERLOAD 1 CLOSE STROKE	*
1o	45-46	OPENS ON OVERLOAD ON OPEN STROKE	**

CONT CLOSED * THIS SHEET

PRC APERTURE CARD

NUCLEAR SAFETY RELATED **WPPSS QUALITY CLASS I**

5 4 3 2 1 REV. DATE BY APPROVED	EBASCO SERVICES INCORPORATED DIV. CONTROL DR. LVT CH. E. OVALLE DATE MAY 5, 1977	APPROVED 	WASHINGTON PUBLIC POWER SUPPLY SYSTEM NUCLEAR PROJECTS NO. 3 & 5 CONTROL WIRING DIAGRAM LPSI PUMP 1 SUCT 150 VA 251-VJOCISAR (31-683)
			WPPSS-3240 D-6001 SHEET 22/17

RIDS

8303090573

