



NOTE
 1. TS TRANSFER SWITCH DEVELOPMENT IS SHOWN ON SH. 2111.

LIMIT SW	POSITION		CWD
	FRONT VIEW		
	UNLOCK	LOCK	
1A	X		*
1B	X		2205
2A	X		2207
2B	X		2217
3A	X		2218
3B	X		2219
4A	X		2221
4B	X		2225
5A		X	*
5B	X		

LIMIT SW DEVELOPMENT			
EBASCO SYMBOL	CONT.	VALVE OPNG. %	
		0	100
ba	1-2		*
ac	3-4		*
bc	5-6		*
ac	7-8		*
aa	9-10		*
bc	11-12		*
aa	13-14		*
bc	15-16		*
a %	17-18		*
b %	19-20		*
a %	21-22		*
b %	23-24		*
h %	25-26		*
a %	27-28		*
b %	29-30		*
a %	31-32		*
tc	35-36	OPENS ON OVERLOAD ON CLOSE STROKE	*
to	45-46	OPENS ON OVERLOAD ON OPEN STROKE	*

PRO APERTURE CARD

NUCLEAR SAFETY RELATED WPPSS QUALITY CLASS I

EBASCO SERVICES INCORPORATED DIV. CONTROL DR. LVT CH. E. OVALLE DATE MAY 5, 1977		WASHINGTON PUBLIC POWER SUPPLY SYSTEM NUCLEAR PROJECTS NO. 3 & 5 CONTROL WIRING DIAGRAM SCHX DISCH TEMP CONTROL VA 251-BOCIAR (SI-657)		WPPS-3240 D-6001 SHEET 2220
---	--	--	--	-----------------------------------

11
11
5.8
8.4
11
19

11
11
5.8
8.5
11
17

RIDS

8303090588

