



**NOTES:**  
 1. TS TRANSFER SWITCH DEVELOPMENT IS SHOWN ON SH. 2111.  
 2. ALL JUMPERS BY FIELD.

CONTACT	POSITION		CWD
	UNLOCK	LOCK	
1	X		*
2	X		2223
3	X		2224
4	X		

KEY REMOVABLE IN LOCK ONLY  
 \* THIS SHEET

LIMIT SW DEVELOPMENT			
EBASCO SYMBOL	CONT.	VALVE OPNG. %	CWD SH.
		0	
		100	
bo	1-2		*
ac	3-4		*
bo	5-6		*
ac	7-8		*
ao	9-10		*
bc	11-12		*
ao	13-14		*
bc	15-16		*
a %	17-18		*
b %	19-20		*
a %	21-22		*
b %	23-24		*
a %	25-26		*
a %	27-28		2306
b %	29-30		*
a %	31-32		*
1c	35-36	OPENS ON OVERLOAD ON CLOSE STROKE	*
1o	45-46	OPENS ON OVERLOAD ON OPEN STROKE	*

PRO APERTURE CARD

REV.	DATE	BY	APPROVED
5			
4			
3			
2	7-2-82	LB LVT	
1	10-23-78	A.R. CD	

**EBASCO SERVICES INCORPORATED**  
 DIV. CONTROL DR. LVT  
 CH. E. OVALLE  
 DATE MAY 5, 1977  
 APPROVED: *[Signature]*

**NUCLEAR SAFETY RELATED**    **WPPSS QUALITY CLASS I**  
 WASHINGTON PUBLIC POWER SUPPLY SYSTEM  
 NUCLEAR PROJECTS NO. 3 & 5  
 CONTROL WIRING DIAGRAM  
 CONTAINMENT SPRAY PUMP DISCH  
 VA 205-VS0155AR (SI-684)

**WPPS-3240**  
**D-6001**  
**SHEET 2222**

SCALE 1/8" = 1'-0" (11-74 400250)

RIDS

6303090597

