



- NOTES:
- TS TRANSFER SWITCH DEVELOPMENT IS SHOWN ON SH. III.
  - ALL JUMPERS BY FIELD

LIMIT SW DEVELOPMENT			
EBASCO SYMBOL	CONT.	VALVE OPNG %	
		0	100
ba	1-2		*
ac	3-4		*
ba	5-6		*
ac	7-8		*
ao	9-10		*
bc	11-12		*
ao	13-14		*
bc	15-16		*
a%	17-18		*
b%	19-20		*
a%	21-22		*
b%	23-24		*
b%	25-26		*
a%	27-28		2306
b%	29-30		*
a%	31-32		*
1c	35-36	OPENS ON OVERLOAD ON CLOSE STROKE	*
1o	45-46	OPENS ON OVERLOAD ON OPEN STROKE	*
CONT. CLOSED * THIS SHEET			

PRC APERTURE CARD

5 4 3 2 7-2-82 LB LVT 10-23-78 AR CDW REV DATE BY APPROVED		EBASCO SERVICES INCORPORATED DIV. CONTROL DR. LVT CH. E. OVALLE DATE MAY 5, 1977		WASHINGTON PUBLIC POWER SUPPLY SYSTEM NUCLEAR PROJECTS NO. 3 & 5 CONTROL WIRING DIAGRAM SCH. 1 TO CONTAINMENT SPRAY HDR 1 ISO VA 205-VS023SAR (SI-687)		WPPS-3240 D-6001 SHEET 2223	
---	--	---	--	--	--	-----------------------------------	--

11  
58  
8.5"  
11"  
17"

RIDS

8303090598

