



NOTES
 1. TS TRANSFER SWITCH DEVELOPMENT IS SHOWN ON SH. 2111.
 2. ALL JUMPERS BY FIELD.

LIMIT SW DEVELOPMENT			
EBASCO SYMBOL	CONT.	VALVE OPNG. %	CWD SH.
		0	
		100	
bo	1-2		*
ac	3-4		*
bo	5-6		*
ac	7-8		*
ao	9-10		*
bc	11-12		*
ao	13-14		*
bc	15-16		*
a%	17-18		*
b%	19-20		*
a%	21-22		*
b%	23-24		*
b%	25-26		*
a%	27-28		*
b%	29-30		*
a%	31-32		*
tc	35-36	OPENS ON OVERLOAD ON CLOSE STROKE	*
to	45-46	OPENS ON OVERLOAD ON OPEN STROKE	*

— CONT. CLOSED * THIS SHEET

PRC APERTURE CARD

5				
4				
3				
2	S-3-82	RJP	V.A.	PLD
1	10-2378	A.R.	W.S.	W.S.
REV.	DATE	BY	APPROVED	
	MAY 5, 1977			

NUCLEAR SAFETY RELATED WPPSS QUALITY CLASS I

EBASCO SERVICES INCORPORATED
 DIV. CONTROL DR. LVT
 CH. E. OVALLE
 DATE MAY 5, 1977

APPROVED
W. Wallach

WASHINGTON PUBLIC POWER SUPPLY SYSTEM
 NUCLEAR PROJECTS NO. 3 & 5
 CONTROL WIRING DIAGRAM
 SHUTDOWN COOLING HEAT EXCH 1 BYPASS
 VA 2CS-VS079 SAR(SI-688)

WPPS-3240
 D-6001
 SHEET 2224

20
 11
 5.0
 8.5
 11
 17

21
 11
 5.8
 8.5
 11
 17

RIDS

8303090600

