



- NOTES
1. TS TRANSFER SWITCH DEVELOPMENT IS SHOWN ON SH. 211
 2. ALL JUMPERS BY FIELD.

LIMIT SW DEVELOPMENT			
EBASCO SYMBOL	CONT.	VALVE OPNG. %	
		0	100
bo	1-2		*
ac	3-4		*
bo	5-6		*
ac	7-8		*
ao	9-10		*
bc	11-12		*
ao	13-14		*
bc	15-16		*
a %	17-18		*
b %	19-20		*
a %	21-22		*
b %	23-24		*
b %	25-26		*
a %	27-28		*
b %	29-30		*
a %	31-32		*
1c	35-36	OPENS ON OVERLOAD ON CLOSE STROKE	*
1o	45-46	OPENS ON OVERLOAD ON OPEN STROKE	*

— CONT. CLOSED * THIS SHEET

NUCLEAR SAFETY RELATED WPPSS QUALITY CLASS I

EBASCO SERVICES INCORPORATED DIV. CONTROL DR. LVT CH. E. JOVALLÉ DATE MAY 5, 1977		APPROVED <i>U. Wallach</i> J. P. ...	
5 4 3 2 8-3-82 RSP V.N. J.P. 1 10-23-78 A.R. J.P.	REV. DATE BY APPROVED	WASHINGTON PUBLIC POWER SUPPLY SYSTEM NUCLEAR PROJECTS NO. 3 & 5 CONTROL WIRING DIAGRAM SHUTDOWN COOLING WARMUP LINE VA 25I-VS054SAR (SI-691)	

WPPS-3240
D-6001
SHEET 2225

P.R.C. APERTURE CARD

17"
11"
8.5"
11"
17"

RIDS

8303090602

