



- NOTES:**
1. TS TRANSFER SWITCH DEVELOPMENT IS SHOWN ON SH. 2112.
 2. ALL JUMPERS BY FIELD

LIMIT SW DEVELOPMENT				
EBASCO SYMBOL	CONT.	VALVE OPNG. %		CWD SH.
		0	100	
bo	1-2			*
ac	3-4			*
bo	5-6			*
ac	7-8			*
ao	9-10			*
bc	11-12			*
ao	13-14			*
bc	15-16			*
a%	17-18			*
b%	19-20			*
a%	21-22			*
b%	23-24			*
b%	25-26			*
a%	27-28			2145
b%	29-30			*
a%	31-32			*
tc	35-36	OPENS ON OVERLOAD ON CLOSE STROKE		*
to	45-46	OPENS ON OVERLOAD ON OPEN STROKE		*

CONT. CLOSED * THIS SHEET

PRC APERTURE CARD

3				
4				
3				
2	7-2-82	LVT	W.A.	
1	10-23-78	A.R.	W.A.	
REV	DATE	BY	APPROVED	

EBASCO SERVICES INCORPORATED
 DIV. CONTROL DR. LVT
 CH. E. OVALLE
 DATE MAY 5, 1977
 APPROVED
U. Wallace

WASHINGTON PUBLIC POWER SUPPLY SYSTEM
 NUCLEAR PROJECTS NO. 3 & 5
 CONTROL WIRING DIAGRAM
 LPSI PUMP 2 SUCT 150
 VA 251-VU0215BR(SI-692)

WPPS-3240
D-6001
 SHEET 2231

RIDS

8303090604

