



NOTES:  
 1. TS TRANSFER SWITCH DEVELOPMENT IS SHOWN ON SH 2112.  
 2. ALL JUMPERS BY FIELD

LIMIT SW DEVELOPMENT			
EBASCO SYMBOL	CONT.	VALVE OPNG. %	CWD SH.
		0	
		100	
bo	1-2		*
ac	3-4		*
bo	5-6		*
ac	7-8		*
ao	9-10		*
bc	11-12		*
ao	13-14		*
bc	15-16		*
a %	17-18		*
b %	19-20		*
a %	21-22		*
b %	23-24		*
b %	25-26		*
a %	27-28		*
b %	29-30		*
a %	31-32		*
tc	35-36	OPENS ON OVERLOAD ON CLOSE STROKE	*
to	45-46	OPENS ON OVERLOAD ON OPEN STROKE	*

CONT. CLOSED \* THIS SHEET

PRC APERTURE CARD

**NUCLEAR SAFETY RELATED WPPSS QUALITY CLASS I**

<b>EBASCO SERVICES INCORPORATED</b> DIV. CONTROL DR. LVT CH. E. OVALLE DATE MAY 5, 1977	APPROVED <i>M. Wallach</i> SUPERVISOR	WASHINGTON PUBLIC POWER SUPPLY SYSTEM NUCLEAR PROJECTS NO. 3 & 5 CONTROL WIRING DIAGRAM LPSI PUMP 2 DISCH SCHX 2 X-COIN ISO VA 2CS-VS018SBR(SI-694)
		<b>WPPS-3240</b> <b>D-6001</b> SHEET 2232

REV.	DATE	BY	APPROVED
5			
4			
3			
2	7-2-82	LB V.A. P.S.P.	
1	10-23-76	AR C.P.L.	

K&E 19 1253 11-74 00233

RIDS

8303090609

