



CONTACT	POSITION		CWD
	FRONT VIEW		
1	X		*
2	X		2237
3	X		2238
4	X		

KEY REMOVABLE IN LOCK ONLY
* THIS SHEET

- NOTES:
- TS TRANSFER SWITCH DEVELOPMENT IS SHOWN ON SH 2112
 - ALL JUMPERS BY FIELD

LIMIT SW DEVELOPMENT			
EBASCO SYMBOL	CONT.	VALVE OPNG. %	CWD SH.
		0	
		100	
bo	1-2		*
ac	3-4		
bo	5-6		*
ac	7-8		
ao	9-10		*
bc	11-12		*
ao	13-14		*
bc	15-16		*
a %	17-18		
b %	19-20		*
a %	21-22		
b %	23-24		
b %	25-26		
a %	27-28		(2307)
b %	29-30		
a %	31-32		
1c	35-36	OPENS ON OVERLOAD ON CLOSE STROKE	*
1o	45-46	OPENS ON OVERLOAD ON OPEN STROKE	*

P.R.C. APERTURE CARD

REV.	DATE	BY	APPROVED
3			
2	7-2-82	LB LVT	NA
1	8-7-73	AR	VA CD
Δ	10-23-78	AR	WCD

EBASCO SERVICES INCORPORATED
 DIV. CONTROL DR. LVT
 CH. E. OVALLE
 DATE MAY 5, 1977
 APPROVED
 W. Wallach

NUCLEAR SAFETY RELATED
 WPPSS QUALITY CLASS I
 WASHINGTON PUBLIC POWER SUPPLY SYSTEM
 NUCLEAR PROJECTS NO. 3 & 5
 CONTROL WIRING DIAGRAM
 CONTAINMENT SPRAY PUMP B DISCH
 VA 205-VS0165BR(SI-689)

WPPSS-3240
 D-6001
 SHEET 2236

RIDS

8303090620

