



- NOTES:
1. TS TRANSFER SWITCH DEVELOPMENT IS SHOWN ON SH. 2112.
 2. ALL JUMPERS BY FIELD

| LIMIT SW DEVELOPMENT | | | |
|----------------------|-------|-----------------------------------|---------|
| EBASCO SYMBOL | CONT. | VALVE OPNG. % | CWD SH. |
| | | 0 | 100 |
| bo | 1-2 | | * |
| ac | 3-4 | | |
| bo | 5-6 | | * |
| ac | 7-8 | | * |
| ao | 9-10 | | * |
| bc | 11-12 | | * |
| ao | 13-14 | | * |
| bc | 15-16 | | |
| a % | 17-18 | | |
| b % | 19-20 | | * |
| a % | 21-22 | | * |
| b % | 23-24 | | |
| b % | 25-26 | | |
| a % | 27-28 | | (2307) |
| b % | 29-30 | | |
| a % | 31-32 | | |
| tc | 35-36 | OPENS ON OVERLOAD ON CLOSE STROKE | * |
| to | 45-46 | OPENS ON OVERLOAD ON OPEN STROKE | * |

--- CONT. CLOSED * THIS SHEET

NUCLEAR SAFETY RELATED WPPSS QUALITY CLASS I

| | | | |
|------------------------------|--|---------------------------------------|--|
| EBASCO SERVICES INCORPORATED | | WASHINGTON PUBLIC POWER SUPPLY SYSTEM | |
| DIV. CONTROL DR. LVT | | APPROVED | |
| CH. E. OVALLE | | DATE MAY 5 1977 | |
| DATE MAY 5 1977 | | VA 2CS-V5024SBR (SI-655) | |

WPPSS-324C
D-6001
SHEET 2237

11
11
58
85
11
17

11
11
58
8.5
11
17

RIDS

8303090624

