



NOTES
 1. TS TRANSFER SWITCH DEVELOPMENT IS SHOWN ON SH. 2112.
 2. ALL JUMPERS BY FIELD.

LIMIT SW DEVELOPMENT			
EBASCO SYMBOL	CONT.	VALVE OPNG. %	CWD SH.
		0	100
ba	1-2		*
ac	3-4		*
ba	5-6		*
ac	7-8		*
ac	9-10		*
bc	11-12		*
aa	13-14		*
bc	15-16		*
a%	17-18		*
b%	19-20		*
a%	21-22		*
b%	23-24		*
b%	25-26		*
a%	27-28		*
b%	29-30		*
a%	31-32		*
1c	35-36	OPENS ON OVERLOAD ON CLOSE STROKE	*
1a	45-46	OPENS ON OVERLOAD ON OPEN STROKE	*

— CONT. CLOSED * THIS SHEET

P.R.C. APERTURE CARD

5				
4				
3				
2	8-3-82	PW	VA	253
1	10-2378	AR	CD	153
REV.	DATE	BY	APPROVED	

EBASCO SERVICES INCORPORATED
 DIV. CONTROL DR. LVT
 CH. E.OVALLE
 DATE MAY 5 1977

APPROVED
 WASHINGTON PUBLIC POWER SUPPLY SYSTEM
 NUCLEAR PROJECTS NO. 3 & 5
 CONTROL WIRING DIAGRAM
 SHUTDOWN COOLING HEAT EXCH 2 BYPASS
 VA 2CS-VS080SBR (SI-693)

WPPSS QUALITY CLASS I
 WPPS-3240
 D-6001
 SHEET 2238

RIDS

8303090625

