



- NOTES**
1. TS TRANSFER SWITCH DEVELOPMENT IS SHOWN ON SH. 2112
 2. ALL JUMPERS BY FIELD.

| LIMIT SW DEVELOPMENT | | | |
|----------------------|-------|-----------------------------------|---------|
| EBASCO SYMBOL | CONT. | VALVE OPNG. % | CWD SH. |
| | | 0 | |
| | | 100 | |
| bo | 1-2 | | * |
| ac | 3-4 | | * |
| bo | 5-6 | | * |
| ac | 7-8 | | * |
| ao | 9-10 | | * |
| bc | 11-12 | | * |
| ao | 13-14 | | * |
| bc | 15-16 | | * |
| a% | 17-18 | | * |
| b% | 19-20 | | * |
| a% | 21-22 | | * |
| b% | 23-24 | | * |
| b% | 25-26 | | * |
| a% | 27-28 | | * |
| b% | 29-30 | | * |
| a% | 31-32 | | * |
| 1c | 35-36 | OPENS ON OVERLOAD ON CLOSE STROKE | * |
| 1o | 45-46 | OPENS ON OVERLOAD ON OPEN STROKE | * |

→ CONT. CLOSED * THIS SHEET

PRC APERTURE CARD

NUCLEAR SAFETY RELATED WPPSS QUALITY CLASS I

| | | | |
|-----------------------------------|---|---|--|
| 5 4 3 2 1 | EBASCO SERVICES INCORPORATED DIV. CONTROL DR. LVT CH. E. OVALLE DATE MAY 5, 1977 | APPROVED <i>U. Wallace</i> DATE MAY 5, 1977 | WASHINGTON PUBLIC POWER SUPPLY SYSTEM NUCLEAR PROJECTS NO. 3 & 5 CONTROL WIRING DIAGRAM SHUTDOWN COOLING WARMUP LINE VA 25I-V506DSBR(SI-690) |
| WPPS-3240 D-6001 SHEET 2239 | | | |

11
 11
 8.5
 8.5
 11
 11
 17

11
 11
 8.5
 8.5
 11
 11
 17

K&E 18 1203 11-76 00533

RIDS

8303090629

