



CS-4

CONTACT	POSITION FRONT VIEW			CWD
	CLOSE	AUTO	0-RIDE	
1	X			*
2			X	*
3	X			
4			X	*

SPRING RETURN TO AUTO WITH KEY LOCK, KEY REMOVABLE IN AUTO ONLY.
* THIS SHEET

NOTE
I. ALL JUMPERS BY FIELD.

LIMIT SW DEVELOPMENT			
EBASCO SYMBOL	CONT.	VALVE OPNG. %	CONT.
ny	1-2	0	24
ac	3-4		
bc	5-6		
cc	7-8		
dc	9-10		
ec	11-12		
fc	13-14		
gc	15-16		
hc	17-18		
ic	19-20		
jc	21-22		
kc	23-24		
lc	25-26		
mc	27-28		
nc	29-30		
oc	31-32		
1c	35-36	OPENS ON OVERLOAD ON CLOSE STROKE	
1o	45-46	OPENS ON OVERLOAD ON OPEN STROKE	

--- CONT. CLOSED * THIS SHEET

5 4 3 2 1		EBASCO SERVICES INCORPORATED DIV. CONTROL DR. LVT CH. E. OVALLE DATE MAY 5 1977		WASHINGTON PUBLIC POWER SUPPLY SYSTEM NUCLEAR PROJECTS NO. 3 & 5 CONTROL WIRING DIAGRAM CONTAINMENT SPRAY ISOLATION VA 2CS-VS09ISA (SI-672)		WPPSS QUALITY CLASS 1 WPPSS-3240 D-6001 SHEET 2279	
-----------------------	--	---	--	--	--	--	--

1250 18 1250 11-78 000534

RIDS

8303090641

