



CS-4

CONTACT	POSITION FRONT VIEW			CWD
	CLOSE	AUTO	OPEN/CSAS 0-RIDE	
1	X			*
2			X	*
3	X			
4			X	*

SPRING RETURN TO AUTO WITH KEY LOCK, KEY REMOVABLE IN AUTO ONLY.
* THIS SHEET

NOTE
I. ALL JUMPERS BY FIELD.

LIMIT SW DEVELOPMENT

EBASCO SYMBOL	CONT.	VALVE OPNG. %		CWD SH.
		0	100	
bp	1-2			*
ac	3-4			
bc	5-6			*
ac	7-8			
ac	9-10			*
bc	11-12			*
ac	13-14			(2307)
bc	15-16			
a %	17-18			
b %	19-20			
a %	21-22			
b %	23-24			
b %	25-26			
a %	27-28			
b %	29-30			
a %	31-32			
tc	35-36	OPENS ON OVERLOAD ON CLOSE STROKE		*
to	45-46	OPENS ON OVERLOAD ON OPEN STROKE		*

CONT. CLOSED * THIS SHEET

PRC APERTURE CARD

NUCLEAR SAFETY RELATED WPPSS QUALITY CLASS I

EBASCO SERVICES INCORPORATED DIV. CONTROL DR. LVT CH. E. OVALLE DATE MAY 5, 1977			APPROVED <i>[Signature]</i> L. H. PAVEL			WASHINGTON PUBLIC POWER SUPPLY SYSTEM NUCLEAR PROJECTS NO. 3 & 5 CONTROL WIRING DIAGRAM CONTAINMENT SPRAY ISOLATION VA 2CS-V50925B (SI-671)			WPPSS-3240 D-6001 SHEET 2280		
---	--	--	---	--	--	---	--	--	------------------------------------	--	--

NSD 18 1255 11-76 480519

RIDS

8303090643

