



- NOTES**
- CONTACT OPENS ON LOW FLOW.
 - CONTACT OPENS ON LOW PRESSURE.
 - CONTACT CLOSURES ON LOW LEVEL.
 - CONTACT CLOSURES ON LOW FLOW.
 - CONTACT OPENS ON HIGH LEVEL.
 - CONTACT OPENS ON HIGH TEMPERATURE.
 - CONTACT OPENS ON HIGH FLOW.
 - CONTACT OPENS ON LOW LEVEL.
 - CONTACT OPENS ON LOW TEMPERATURE.
 - CONTACT OPENS WHEN FIC-CS0318AS IS IN MANUAL.
 - CONTACT OPENS ON POWER SUPPLY FAILURE.
 - FIELD TO ADD JUMPERS INTERNALLY.
- LEGEND**
* - THIS SHEET

PRC
APERTURE
CARD

NUCLEAR SAFETY RELATED WPPSS QUALITY CLASS I

5 6-7-82 8-7-81 5-29-81 5-13-79		EBASCO SERVICES INCORPORATED DIV. CONTROL DR. PAIVA CH. A. SEN DATE MAY 12, 1978		APPROVED 		WASHINGTON PUBLIC POWER SUPPLY SYSTEM NUCLEAR PROJECT NO. 3 & 8 CONTROL WIRING DIAGRAM CONTAINMENT SPRAY SA INSTRUMENTATION		WPPSS-324 D-6001 SHEET 2808	
---	--	---	--	--------------	--	--	--	-----------------------------------	--

PLATE 19 1583 1174 40938

RIDS

8303090645

