



CONTACT	POSITION FRONT VIEW		CWD
	CLOSE/AS CO-RIDE	AUTO OFEN	
1	X		*
2		X	*
3	X		*
4		X	*

SPRING RETURN TO AUTO WITH KEY LOCK KEY REMOVABLE IN AUTO ONLY.

* THIS SHEET

NOTES

1. FIELD TO WIRE CONTACTS.
2. FIELD TO JUMPER INTERNALLY.
3. FIELD TO VERIFY IF JUMPERS ARE INSTALLED. IF NOT FIELD TO ADD JUMPERS.

CONT'D ON SH. 2282 NOTE 2

CONT'D ON SH. 2282 NOTE 2

LIMIT SW DEVELOPMENT			
EBASCO SYMBOL	CONT.	VALVE OPNG. %	CWD SH.
bo	1-2		*
ac	3-4		*
bo	5-6		*
ac	7-8		*
ao	9-10		*
bc	11-12		*
ao	13-14		*
bc	15-16		*
ao	17-18		*
ao	19-20		*
ao	21-22		*
b	23-24		*
b	25-26		*
b	27-28		*
b	29-30		*
b	31-32		*
1c	35-36	SENS ON OVERLOAD ON CLOSE STROKE	*
1c	45-46	SENS ON OVERLOAD ON OPEN STROKE	*
CONT. CLOSED * THIS SHEET			

PRC APERTURE CARD

NUCLEAR SAFETY RELATED WPPSS QUALITY CLASS I		EBASCO SERVICES INCORPORATED DIV. CONTROL DR. LVT EN. E. O'VALLE DATE MAY 5, 1977		APPROVED <i>U. Wallach</i> H. PAVEL		WASHINGTON PUBLIC POWER SUPPLY SYSTEM NUCLEAR PROJECTS NO. 3 & 5 CONTROL WIRING DIAGRAM GS PUMP A MIN FLOW ISO VA 2CS-VQ005 SAR (SI-664)		WPPSS-3240 D-6001 SHEET 2285	
---	--	--	--	---	--	--	--	------------------------------------	--

44
44
50
85
11
17

44
44
58
8.5
11
17

RIDS

8303090650

