



LIMIT SW DEVELOPMENT			
EBASCO SYMBOL	CONT.	VALVE OPNG. %	CWD SH.
bo	1-2		
ac	3-4		
bo	5-6		*
ac	7-8		*
ao	9-10		
bc	11-12		
ao	13-14		*
bc	15-16		*
a %	17-18		
b %	19-20		
a %	21-22		
b %	23-24		
b %	25-26		
a %	27-28		
b %	29-30		
a %	31-32		
1c	35-36	OPENS ON OVERLOAD ON CLOSE STROKE	*
1o	45-46	OPENS ON OVERLOAD ON OPEN STROKE	*

- NOTES
- CONTACT CLOSES ON HIGH CHEMICAL FLOW.
 - CONTACT CLOSES ON SPRAY CHEMICAL STORAGE TANK LOW LEVEL.
 - CONTACT CLOSES ON LOW CONTAINMENT SPRAY FLOW.
 - JUMPERS BY FIELD.

APERTURE CARD

ERASCO SERVICES INCORPORATED		WASHINGTON PUBLIC POWER SUPPLY SYSTEM	
DIV. CONTROL DR. C. KIM		NUCLEAR PROJECTS NO. 3 & 5	
GM. A. R. RAO		CONTROL WIRING DIAGRAM	
DATE MARCH 9 1979		CHEMICAL INJECTION TO SPRAY SUCTION	
		VA 2CS-VU055SAR	
		WPPSS QUALITY CLASS I	
		WPPS-924C	
		D-6001	
		SHEET 2301	

11
14
50
11
17

11
11
98
8.5"
11"
17"

RIDS

8303090658

