



CS-3

COL. TACT	POSITION FRONT VIEW			CWD
	CLOSE	NORM	OPEN	
1	X			*
2			X	*
3	X			
4			X	

SPRING RETURN TO NORM WITH KEY LOCK, KEY REMOVABLE IN NORM ONLY
 * THIS SHEET

LIMIT SW DEVELOPMENT

EBASCO SYMBOL	CONT.	VALVE OPNG. %	CWD SH.
bo	1-2	0	*
cc	3-4	0	*
bo	5-6	0	*
cc	7-8	0	*
co	9-10	0	*
bc	11-12	0	*
co	13-14	0	*
bc	15-16	0	*
a %	17-18	0	*
b %	19-20	0	*
a %	21-22	0	*
b %	23-24	0	*
b %	25-26	0	*
a %	27-28	0	*
b %	29-30	0	*
a %	31-32	0	*
tc	33-36	OPEN ON OVERLOAD ON CLOSE STROKE	*
to	45-46	OPEN ON OVERLOAD ON OPEN STROKE	*

CONT. CLOSED * THIS SHEET

PRO APERTURE CARD

NUCLEAR SAFETY RELATED WPPSS QUALITY CLASS I

4-12-80 8-18-79 REV. DATE BY APPROVED	EDASCO SERVICES INCORPORATED DIV. CONTROL OR. LVT CH. E. OVALLE DATE MAY 5, 1977	WASHINGTON PUBLIC POWER SUPPLY SYSTEM NUCLEAR PROJECTS NO. 3 & 5 CONTROL WIRING DIAGRAM CONTAINMENT BRAY PUMP B-SB FLOW CONTROL VA 2CS-FD015BR (S1-679)	WPPS-3240 D-6001 SHEET 2305
---	---	--	-----------------------------------

RIDS

8303090666

