



LIMIT SW DEVELOPMENT

EBASCO SYMBOL	CONT.	VALVE OPNG. %	CWD SH.
		0	100
bc	1-2		*
ac	3-4		
bc	5-6		*
ac	7-8		*
aa	9-10		*
bc	11-12		*
aa	13-14		
bc	15-16		
a %	17-18		
b %	19-20		
a %	21-22		
b %	23-24		
b %	25-26		
a %	27-28		
b %	29-30		
a %	31-32		
1c	35-36	OPENS ON OVERLOAD ON CLOSE STROKE	*
1a	45-46	OPENS ON OVERLOAD ON OPEN STROKE	*

--- CONT. CLOSED * THIS SHEET

PRC APERTURE CARD

WPPSS QUALITY CLASS II

5							
4							
3							
2	1-23-81	RJP	NA				
1	9-14-79	A.R.	NA				
REV.	DATE	BY	APPROVED				

EBASCO SERVICES INCORPORATED
 DIV. CONTROL OR. HSM
 CH. A. R. RAO
 DATE JUNE 15, 1979

WASHINGTON PUBLIC POWER SUPPLY SYSTEM
 NUCLEAR PROJECTS NO. 3 & 5
 CONTROL WIRING DIAGRAM
 STM GEN 2-MAIN STM TO SAMPLE COOLERS VA SMS-VC 136

WPPSS-3240
 D-6001
 SHEET 2382

NOTE 10 1589 11-78 48955P

RIDS

8303090669

