



| LIMIT SW DEVELOPMENT | | | |
|----------------------|-------|-----------------------------------|---------|
| EBASCO SYMBOL | CONT. | VALVE OPNG. % | CWD SH. |
| | | 0 | 100 |
| bo | 1-2 | | ** |
| ac | 3-4 | | ** |
| bo | 5-6 | | ** |
| ac | 7-8 | | ** |
| ao | 9-10 | | ** |
| bc | 11-12 | | ** |
| ao | 13-14 | | ** |
| bc | 15-16 | | ** |
| a % | 17-18 | | |
| b % | 19-20 | | |
| a % | 21-22 | | |
| b % | 23-24 | | |
| b % | 25-26 | | |
| a % | 27-28 | | |
| b % | 29-30 | | |
| a % | 31-32 | | |
| 1c | 35-36 | OPENS ON OVERLOAD ON CLOSE STROKE | ** |
| 1o | 45-46 | OPENS ON OVERLOAD ON OPEN STROKE | ** |

— CONT. CLOSED * THIS SHEET

PRC APERTURE CARD

NUCLEAR SAFETY RELATED WPPSS QUALITY CLASS I

| | | | | | | | | |
|-----------------------|-----|--|------------------------------|--|---------------------------------------|--|------------|--|
| REV. DATE BY APPROVED | | | EDASCO SERVICES INCORPORATED | | WASHINGTON PUBLIC POWER SUPPLY SYSTEM | | WPPS-9240 | |
| 10-15-81 | RJP | | DIV. CONTROL DR. HSM | | NUCLEAR PROJECTS NO. 3 & 5 | | D-6001 | |
| 6-26-81 | RJP | | CH. VALKENINIS | | CONTROL WIRING DIAGRAM | | SHEET 2391 | |
| 6-12-80 | RJP | | DATE SEP 1, 1978 | | SG 1 FEEDWATER ISOL VA | | | |
| | | | | | 2FW-VD022 SA | | | |

11
11
8.5
8.5
11
17

11
11
8.5
8.5
11
17

RWS

8303090689

