



- NOTES:**
1. CONTACT OPENS ON HIGH TEMP.
  2. CONTACT OPENS ON LOW FLOW.
  3. CONTACT OPENS ON LOW CCW SURGE TANK B LEVEL.
  4. CONTACT OPENS ON HIGH CCW SURGE TANK B LEVEL.
  5. CONTACT OPENS ON HIGH RATE OF LEVEL CHANGE.

PRC  
APERTURE  
CARD

NUCLEAR SAFETY RELATED WPPSS QUALITY CLASS I & D

EASCO SERVICES INCORPORATED			
DIV. CONTROL DR. PAINA		APPROVED	
CH. ASEN		<i>[Signature]</i>	
DATE MAY 12, 1978		<i>[Signature]</i>	
REV	DATE	BY	APPROVED
5	7-23-82	GA	<i>[Signature]</i>
4	3-26-82	GA	<i>[Signature]</i>
3	7-16-81	GA	<i>[Signature]</i>
2	3-16-79	LNT	<i>[Signature]</i>

WASHINGTON PUBLIC POWER  
SUPPLY SYSTEM  
NUCLEAR PROJECTS NO. 3 & 4  
CONTROL WIRING DIAGRAM  
COMPONENT COOLING WATER 'SB  
INSTRUMENTATION SM. 1

WPPSS 3240  
D-8001  
SHEET 247E

RWS

8303100147

