



NOTES
 1. TS TRANSFER SWITCH DEVELOPMENT IS SHOWN ON SH. 2M.
 2. CONTACT CLOSES ON HIGH RATE OF EXPANSION OF CCW SURGE TANK A.

| LIMIT SW DEVELOPMENT | | |
|-------------------------------|-------|-------------------------------------|
| EBASCO SYMBOL | CONT. | VALVE OPNG. % CWD SH. |
| bo | 1-2 | * |
| ac | 3-4 | * |
| bo | 5-6 | * |
| ac | 7-8 | a |
| ao | 9-10 | * |
| bc | 11-12 | * |
| ao | 13-14 | * |
| bc | 15-16 | * |
| a % | 17-18 | * |
| b % | 19-20 | * |
| a % | 21-22 | * |
| b % | 23-24 | * |
| b % | 25-26 | * |
| a % | 27-28 | * |
| b % | 29-30 | * |
| a % | 31-32 | * |
| 1c | 33-36 | OPENS ON OVERLOAD ON CLOSE STROKE * |
| 1o | 45-46 | OPENS ON OVERLOAD ON OPEN STROKE * |
| --- CONT. CLOSED * THIS SHEET | | |

PRC
 APERI
 CARD

| | | | | | | | | | | | | | |
|---|--|--|--|---|--|--|--|---|--|--|--|---|--|
| 7-15-82 12-19-81 5-8-81 10-23-81 | | | | EBASCO SERVICES INCORPORATED DIV. CONTROL DR. B-SHATAK CH. E. OVALLE DATE: JULY 5, 1977 | | | | WASHINGTON PUBLIC POWER SUPPLY SYSTEM NUCLEAR PROJECTS NO. 3 & 5 CONTROL WIRING DIAGRAM NNS SUPPLY HDR A ISO VA 3CC-B513SA | | | | WPPSS-324C D-6001 SHEET 2511 | |
| REV. DATE BY APPROVED | | | | APPROVED <i>(Signature)</i> | | | | NUCLEAR SAFETY RELATED | | | | WPPSS QUALITY CLASS I | |

RIDS

8303100/85

