



NOTE:
 1. TS TRANSFER SWITCH DEVELOPMENT IS SHOWN ON SH. 2112.

LIMIT SW DEVELOPMENT			
EBASCO SYMBOL	CONT	VALVE OPNG. %	CWD SH.
bp	1-2	0	"
ac	3-4	100	"
bo	5-6	0	"
ac	7-8	100	"
ao	9-10	0	"
bc	11-12	100	"
ao	13-14	0	"
bc	15-16	100	"
a %	17-18	0	"
b %	19-20	100	"
a %	21-22	0	"
b %	23-24	100	"
b %	25-26	0	"
a %	27-28	100	"
b %	29-30	0	"
a %	31-32	100	"
1c	35-36	OPENS ON OVERLOAD ON CLOSE STROKE	*
1o	45-46	OPENS ON OVERLOAD ON OPEN STROKE	*

CONT. CLOSED * THIS SHEET

PRC APERTURE CARD

NUCLEAR SAFETY RELATED WPPSS QUALITY CLASS I

8 4 8 2 12-23-81 R.P. [Signature] 1 10-23-78 A.R. [Signature] REV. DATE BY APPROVED	EBASCO SERVICES INCORPORATED DIV. CONTROL DR. R. GHATAK CH. E. OVALLE DATE: JULY 5, 1977	APPROVED [Signature] LIPAVEL [Signature]	WASHINGTON PUBLIC POWER SUPPLY SYSTEM NUCLEAR PROJECTS NO. 3 & 5 CONTROL WIRING DIAGRAM RCP COOLERS & NNS RETURN HDR B ISO VA 3CC-B5105B
--	--	--	---

WPPS-3240 D-6001 SHEET 2520

RIDS

8303100206

