



- NOTES**
- \*\*\* FIELD TO DISCONNECT.
  - FIELD TO REWIRE.
  - VALVE WAS PURCHASED FOR INSIDE CONTAINMENT USE, BUT IS USED FOR OUTSIDE CONTAINMENT.

SWITCH	EBASCO SYMBOL	LIMIT SW DEVELOPMENT		CWD SH.
		CONT.	VALVE OPNG. %	
		0	100	
LSO-1	bo	5-12		*
LSC-2	ac	8-10		*
LSO-2	bo	8-9		*
LSC-1	ac	13-11		*
LSO-1	ao	5-7		
LSC-2	bc	8-15		
LSO-2	ao	8-16		
LSC-1	bc	13-14		(*)
LSA-1	ac	17-13		
LSB-1	bo	23-23		
LSA-2	ac	20-21		(*)
LSB-2	bo	26-27		
LSA-1	bc	17-19		
LSB-1	ao	23-25		(*)
LSA-2	bc	20-22		
LSB-2	ao	26-28		
TSC	1c	35-36	OPENS ON OVERLOAD ON CLOSE STROKE	*
TSO	1o	45-46	OPENS ON OVERLOAD ON OPEN STROKE	*

CONT. CLOSED \* THIS SHEET

PRC APERTURE CARD

(-11487, -15193) NOTE 3  
MOV LIMIT SWITCHES

NUCLEAR SAFETY RELATED WPPSS QUALITY CLASS 1

5									
4	12-23-81	EV	VA						
	5-8-81	RUP	VA						
	4-25-80	LVT	VA						
	3-7-77	CD	VA						
REV.	DATE	BY	APPROVED	EBASCO SERVICES INCORPORATED		WASHINGTON PUBLIC POWER SUPPLY SYSTEM		WPPS-3240	
				DIV. CONTROL DR. R. GHATAK		NUCLEAR PROJECTS NO. 3 & 5		D-6001	
				CH. E. OVALLE		CONTROL WIRING DIAGRAM		SHEET 2545	
				DATE JULY 5, 1977		RCPIA, 1B COOLERS SUPPLY			
						CONTMT ISO VA 2CC-B521SE			

RIDS

8303/00222

