



- NOTES**
- \*\*\* FIELD TO DISCONNECT.
  - FIELD TO REWIRE.
  - VALVE WAS PURCHASED FOR INSIDE CONTAINMENT USE, BUT IS USED FOR OUTSIDE CONTAINMENT.

SWITCH SYMBOL	EBASCO SYMBOL	CONT.	LIMIT SW DEVELOPMENT		CWD SH.
			VALVE OPNG. %		
			0	100	
LSO-1	bo	5-12			*
LSC-2	ac	8-10			*
LSO-2	bo	8-9			*
LSC-1	ac	13-11			
LSO-1	ao	5-7			
LSC-2	bc	8-15			
LSO-2	ao	8-16			
LSC-1	bc	13-14			*
LSA-1	ac	17-18			
LSB-1	bo	23-21			
LSA-2	ac	20-21			*
LSB-2	bo	26-27			
LSA-1	bc	17-19			
LSB-1	ao	23-25			*
LSA-2	bc	20-22			
LSB-2	ao	26-28			
TSC	1c	35-36	OPENS ON OVERLOAD ON CLOSE STROKE		*
TSO	1o	45-46	OPENS ON OVERLOAD ON OPEN STROKE		*

--- CONT. CLOSED \* THIS SHEET

PRC APERTURE CARD

NUCLEAR SAFETY RELATED WPPSS QUALITY CLASS I

EBASCO SERVICES INCORPORATED DIV. CONTROL DR. R. GHATAK CH. E. OVALLE DATE JULY 5, 1977				APPROVED <i>U. Wallach</i> H. PAVEL		WASHINGTON PUBLIC POWER SUPPLY SYSTEM NUCLEAR PROJECTS NO. 3 & 5 CONTROL WIRING DIAGRAM RCP2A, 2B COOLERS SUPPLY CONTMNT ISO VA 2CC-B522SB		WPPS-9240 D-6001 SHEET 2550	
REV.	DATE	BY	APPROVED						
3									
4									
5	12-23-81	EM							
6	4-23-80	EM							
7	3-7-79	A.R.							

RIDS

8303100228

